



NOTES:

1. THIS DETAIL IS APPROPRIATE FOR 1 & 2 STORY RESIDENTIAL STRUCTURES CONSTRUCTED IN ACCORDANCE WITH THE 2006/2009/2012 IRC SECTIONS R302.2.2.2, R602.3(1) & R602.10.
2. CANTILEVERED JOISTS MUST BE PROPERLY SIZED TO SUPPORT ALL DESIGN LOADS.
3. APPLICATIONS THAT FALL OUTSIDE OF THE SCOPE OF THE 2006/2009/2012 IRC SHALL BE DESIGNED IN ACCORDANCE WITH THE 2006/2009/2012 IBC..
4. NAIL SIZES PER 2006/2009/2012 IRC.
 - 8d = 2 1/2"x0.113"
 - 10d = 3"x0.128"
 - 16d = 3 1/2"x0.135"

PJI CANTILEVER DETAIL